

# MARICOPA COUNTY HEALTH CODE

## CHAPTER VI

### BATHING PLACES - PUBLIC AND SEMIPUBLIC SWIMMING POOLS

#### SECTION 5

#### BATHHOUSE AND DRESSING ROOM FACILITIES

##### REGULATION 1. For All Swimming Pools

- a. The general layout of bathhouses shall be such that bathers leaving the dressing room pass the toilets and showers, in sequence before entering the pool.
- b. Separate dressing rooms shall be provided for each sex and equipped with baskets or other checking facilities adequate for the maximum number of people to be accommodated.
- c. All entrances to, and exits from, the dressing rooms shall be effectively screened to interrupt the line of sight of persons outside the dressing rooms.
- d. Walls and partitions of dressing rooms, lockers rooms, toilets and showers shall be light colored, smooth, nonabsorbent, and easily cleanable. Concrete or pumice blocks used for interior wall construction in these locations shall be finished and sealed to provide an easily cleanable surface.
- e. Floors shall be of nonslip construction, free of open cracks and sloped to adequate drains so that the surface will be free of standing water and puddles.
- f. All furniture shall be of simple character and easily cleanable. Locker compartments, partitions, furniture and other appurtenances to dressing rooms shall be so installed or raised above the floor to permit thorough cleaning and flushing down the dressing rooms and bathhouse interior.
- g. Hose bibs shall be provided for flushing down the dressing rooms and bathhouse interior.
- h. Dressing rooms, toilets and showers shall be provided with adequate lighting and ventilation.
- i. Toilet facilities shall be provided for each sex in accordance with the table below.

##### MEN

1 toilet for each 100 bathers or fraction thereof.

1 urinal for each 100 bathers or fraction thereof.

##### WOMEN

1 toilet for each 50 bathers, or fraction thereof, but in no case shall less than 2 toilets be provided.

- j. Shower and handwashing facilities with hot and cold water and soap shall be provided for each sex in accordance with the table below. Tempered water only shall be provided at all shower heads. The water heater and thermostatic mixing valve shall be inaccessible to bathers and shall be capable of providing 2 gpm of 90°F. water to each shower head.

MEN OR WOMEN

1 shower for each 50 bathers or fraction thereof.

1 lavatory with mirror for each 100 bathers or fraction thereof.